

2025 Annual Drinking Water Quality Report

Remington Water District

We're pleased to present to you the 2025 Annual Quality Water Report (Consumer Confidence Report). This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is three 500'+/- wells drilled into the Rathdrum Prairie Aquifer. As of year end 2025, we had 421 service connections serving a population of 1,137.

We are pleased to report that our drinking water is safe and exceeds federal and state requirements.

If you have any questions about this report or concerning your water service, please contact **Bob Kuch, Licensed Water Operator, at 208-683-0500**. We want our valued customers to be informed about their water service. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the **3rd Wednesday of every month at 6:30pm. at the Athol Community Center, corner of Hwy 54 & 3rd, Athol, Idaho.**

Remington Water District routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of **January 1st to December 31st, 2025** unless otherwise indicated. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk.

What does this mean?

MCL's (Maximum Contaminant Levels - see definitions below) are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having a health effect.

As you can see by the table below, our system had no violations. We're proud that your drinking water exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected. However, the EPA has determined that your water IS safe as we at Remington Water District work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office if you have questions.

2025 Consumer Confidence Report (CCR)

I. Water System Information

Water System Name: Remington Water District	PWS ID #: 1280270
Water System Operator: Bob Kuchenski	
Address: PO Box 468	Tel #: 208-683-0500
City, State, Zip Code: Athol, ID 83801	
Population Served: 1,137	Number of Connections: 421
Date of CCR Distribution: 6/17/2026	For Calendar Year: 2025
Regularly Scheduled Meeting(s): 3 rd Wednesday of each month, 6:30pm at the Athol Community Center.	

II. Water Sources

Groundwater Sources (springs, wells, infiltration galleries):	
1) Source #: 1	a) Sample Site Location: Well field
	b) Location Description: west end of Shoshone
Groundwater/Surface Water Contamination Sources (if known): Erosion of natural deposits	
Source Water Assessment or Protection Plan Available? Yes. The Remington Water District wells are ranked moderately susceptible to all classes of regulated contaminants. Natural risk factors associated with local geology account for most of the points in the final susceptibility scores. A copy of the Source Water Assessment Report is available online at http://www2.deq.idaho.gov/water/swaOnline/Search	

III. Definitions

Action Level (AL): The concentration of a contaminant, which, if exceeded, triggers treatment, or other requirements which a water system must follow.
Maximum Contamination Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum Contamination Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.
Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.
WAIVER (Waived) - Waivers are granted for chemicals known to NOT be contained within a geographic area. The Remington Water District is within the Rathdrum Prairie Aquifer Wellhead Protection Area, which is protected from certain contaminants by the State of Idaho.

IV. Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants

can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800)426-4791 or <http://www.epa.gov/safewater/hotline/>.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800)426-4791 or <http://www.epa.gov/safewater/hotline/>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants that may be present in source water before we treat it include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Lead Informational Statement (Health effects and ways to reduce exposure)

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Remington Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components.

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

V. Level of Detected Chemical and Radiological Contaminants and Associated Health Effects Language

Unless otherwise noted, the data presented in this water quality table is from testing done between January 1 - December 31, 2025.

Contaminant	Violation (Y/N)	MCL	MCLG	Lowest Level Detected:	Highest Level Detected:	Date Tested (mm/yy):	Typical Source of Contamination	Health Effects Language
Arsenic (ppb)	N	10	0	1.3	1.3	3/25	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.	
Barium (ppm)	N	2	2	.027	.027	2/24	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.	
Combined Radium 226 & 228 (PCI/L)	N	30	0	.554	.554	12/23	Erosion of natural deposits.	
Combined Uranium (ug/L)	N	30	0	2.82	2.82	12/23	Erosion of natural deposits	
Fluoride (ppm)	N	4	0	.099	.099	2/24	Erosion of natural deposits.	
Nitrate (ppm)	N	10	10	.258	.258	3/25	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.	
Radium 226 (PCI/L)	N	30	0	.052	.052	12/23	Erosion of natural deposits.	
Radium 228 (PCI/L)	N	30	0	.502	.502	12/23	Erosion of natural deposits.	

VI. Level of Detected Contaminants and Associated Health Effects Language for Systems that must comply with the Disinfection by Products Rule, Surface Water Treatment Rule, and the Long Term 1 Enhanced Surface Water Treatment Rule.

Unless otherwise noted, the data presented in this water quality table is from testing done between January 1 - December 31, 2025.

Contaminant	Violation (Y/N)	MCL	MCLG	Highest Level Detected	Running Annual Average	Sample Date	Typical Source of Contamination	Health Effects Language (include only if system exceeds MCL)
Maximum Residual Disinfectant Level								
Chlorine (ppm)	N	MRDL= 4	n/a	.1	.1	Monthly	Water additive used to control microbes	

Bacteria

	MCL	MCLG	Highest # Positive In a Month	Violation (Y/N)	Possible Source of Contamination	Health Effects Language
Total Coliform	> 1	0	0	N		

VII. Reporting Lead/Copper.

Contaminant	Date(s) Collected	90th Percentile	Action Level	MCLG	#of sites above Action Level	Violation Y/N	Possible Source of Contamination
Lead (ppb)	9/24	0	15	0	0	N	Corrosion of household plumbing systems: Erosion of natural deposits.
Copper (ppm)	9/24	.052	1.3	1.3	0	N	Corrosion of household plumbing systems: Erosion of natural deposits.